



MARSHALL DAY
Acoustics 

35 & 69-93 HAMS ROAD, WAURN PONDS
TRAFFIC NOISE ASSESSMENT
Rp 001 R03 20171434 | 11 October 2018

Project: 35 AND 69-93 HAMS ROAD, WAURN PONDS

Prepared for: **Waurn Ponds Unit Trust** **Echin Pty Ltd**
C/- Urban Quarter WA **C/- 3 Coleman Street #4-30**
Level 2 **Singapore 179804**
48 Kishorn Road
Applecross
WA 6153

Attention: **Mr Roger Cooper**

Report No.: **Rp 001 R03 20171434**

Disclaimer

Reports produced by Marshall Day Acoustics Pty Ltd are based on a specific scope, conditions and limitations, as agreed between Marshall Day Acoustics and the Client. Information and/or report(s) prepared by Marshall Day Acoustics may not be suitable for uses other than the specific project. No parties other than the Client should use any information and/or report(s) without first conferring with Marshall Day Acoustics.

The advice given herein is for acoustic purposes only. Relevant authorities and experts should be consulted with regard to compliance with regulations or requirements governing areas other than acoustics.

Copyright

The concepts and information contained in this document are the property of Marshall Day Acoustics Pty Ltd. Use or copying of this document in whole or in part without the written permission of Marshall Day Acoustics constitutes an infringement of copyright. Information shall not be assigned to a third party without prior consent.

Document Control

Status:	Rev:	Comments	Date:	Author:	Reviewer:
First	-	-	09/03/2018	SJM	GL
Second	1	Revised Masterplan	03/04/2018	SJM	GL
Second	2	Revised Masterplan	08/05/2018	SJM	GL
Final	3	Revised Masterplan	11/10/2018	SJM	GL

TABLE OF CONTENTS

1.0	INTRODUCTION	5
2.0	SITE LOCATION AND SURROUNDINGS	6
2.1	Project description	7
2.2	PTV Referral Comments	7
2.3	Noise considerations.....	8
3.0	EXISTING NOISE ENVIRONMENT	9
3.1	Unattended measurement data - traffic.....	9
3.2	Unattended measurement data – rail.....	10
3.3	Weather conditions	10
4.0	NOISE GUIDELINES	11
5.0	PRELIMINARY TRAFFIC NOISE ASSESSMENT.....	12
5.1	Traffic volumes	12
5.1.1	Predicted traffic noise levels	12
6.0	PRELIMINARY RAIL NOISE ASSESSMENT	14
6.1	Daily rail usage.....	14
6.2	Maximum noise levels due to trains.....	14
6.3	Victorian Passenger Rail Infrastructure Noise Policy.....	14
6.4	Waurn Ponds train stabling facility.....	15
7.0	RECOMMENDED CONSTRUCTIONS.....	16
7.1	Road traffic noise – Geelong Ring Road	16
7.1.1	VicRoads Policy	16
7.1.2	AS2107	16
7.2	Road traffic noise – Baanip Boulevard	17
7.2.1	VicRoads Policy	17
7.2.2	AS2107.....	17
7.3	Road traffic noise – Hams Road	17
7.4	Road traffic noise – Ghazeepore Road	17
7.5	Railway noise	18
7.6	Notes on building constructions	19
8.0	CONCLUSION	20

APPENDIX A GLOSSARY OF TERMINOLOGY

APPENDIX B INDICATIVE SITE LAYOUT PLAN

APPENDIX C UNATTENDED NOISE MONITORING LOCATIONS

APPENDIX D UNATTENDED NOISE MONITORING METHODOLOGY

APPENDIX E UNATTENDED NOISE MONITORING RESULTS – LOCATION 1

APPENDIX F UNATTENDED NOISE MONITORING RESULTS – LOCATION 2

APPENDIX G UNATTENDED NOISE MONITORING RESULTS – LOCATION 3

APPENDIX H UNATTENDED NOISE MONITORING RESULTS – LOCATION 4

APPENDIX I UNATTENDED NOISE MONITORING RESULTS – LOCATION 5

APPENDIX J NOISE GUIDELINES

APPENDIX K NOISE AND WEATHER DATA

1.0 INTRODUCTION

Taylor's Development Strategists Pty Ltd, on behalf of Echin Pty Ltd and Waurin Ponds Unit Trust C/o Urban Quarter WA, are working on the development of land for residential use at 35 and 69 - 93 Hams Road in Waurin Ponds. Marshall Day Acoustics (MDA) has been requested to provide acoustic input for a town planning application for approximately 270 residential lots that abut Baanip Boulevard to the south and Geelong Ring Road to the west.

MDA measured traffic (Geelong Ring Road, Hams Road and Ghazeeopore Road) and train noise levels at the site in 2013 (refer MDA report Rp001 R04 2013193ML, dated 10 June 2014).

Baanip Boulevard was opened in 2015 which links Geelong Ring Road to the west of the site to Ghazeeopore Road that abuts the eastern boundary of the site. Due to the new traffic conditions it is considered important to re-assess noise from Ghazeeopore Road.

However, in the interim since the MDA report was prepared, it is understood that the parcel of land between the existing Powercor substation in the north east corner of the site and the railway to the south will be utilised as a retarding basin (RB2 on the concept plan). As such, the boundary of lots to the east end of the site will now be set back from Ghazeeopore road by approximately 100 m. Therefore, traffic noise to the Ghazeeopore Road side of the site is likely to be less significant than rail noise.

In addition, there is a Powercor substation to the north east corner of the site. Watson Moss Growcott (WMG) undertook an assessment of noise from this facility in November 2017 which identified that it may exceed the applicable NIRV Recommended Maximum Noise Levels at several proposed lots within the development.

This report has been prepared to address potential noise impacts on the development due to adjacent roads and the Geelong/Warrnambool railway line to the south.

Noise due to the Powercor substation will be addressed separately.

Acoustic terminology used in this report is described in Appendix A.

2.0 SITE LOCATION AND SURROUNDINGS

The site is located at 35 and 69 - 93 Hams Road, Waurm Ponds and is bounded by:

- Hams Road to the north
- Geelong/Warrnambool railway line to the south with Baanip Boulevard beyond
- Powercor Waurm Ponds Terminal Station and Ghazeepore Road to the east
- Geelong Ring Road to Anglesea to the west.

An aerial photo of the site is shown in Figure 1 and a site development concept plan is presented in Figure 1.


Figure 1: Site and surroundings (Source: Nearmap)



2.1 Project description

The development of the site will be exclusively residential, an indicative site drawing is presented in Figure 2.

Figure 2: Indicative site layout



2.2 PTV Referral Comments

Public Transport Victoria (PTV) provided referral comments in regard to the initial MDA report in a letter (ref: C372 Planning Permits 662-2017 & 663-2017), which requested the following with respect to noise:

The road and rail acoustic assessment which was undertaken as part of this proposal does not take into consideration a future Waurn Ponds train stabling facility which is being proposed south west of the site. The location for the Waurn Ponds train stabling facility has been selected and the site is proposed to be operational by the end of 2019. In addition, track duplication will also occur between South Geelong and the Waurn Ponds stabling site.

It is anticipated train services between the Waurn Ponds stabling site and the Waurn Ponds station will increase. Freight services are also expected to increase in future.

Given that passenger and freight train services which extend adjacent to the site will increase both during the day and at night the acoustic assessment should accurately reflect the increase in services and outline what potential acoustic mitigation measures may be required as part of the future development of the site.

Noise due to the future train stabling facility is addressed herein as Section 6.4 and changes in noise level due to an increase in train pass-bys is addressed in Section 7.5.

2.3 Noise considerations

The proposed residential development will be impacted by the following sources:

- Train noise from the adjacent railway line
- Noise due to the future train stabling facility
- Traffic noise from the Geelong Ring Road and Baanip Boulevard
- Local commercial or industrial sites and associated operations (e.g. Powercor, which will be assessed by others).

Building facade insulation requirements to protect the amenity of future occupants from external rail and traffic noise will control the acoustic design of the building envelope. Noise from the other sources should comply with relevant statutory legislation or acceptable guidelines, as discussed herein.

3.0 EXISTING NOISE ENVIRONMENT

Consecutive measurements of road traffic noise levels were obtained at the western and southern boundaries of the site in order to calculate the existing traffic noise level in accordance with VicRoads *Traffic Noise Policy RDN 06-01*.

The measurement locations were selected so as to be representative of the facade of the nearest future dwelling to roads in the vicinity. It was observed that the prevailing noise environment was dominated by road traffic on Geelong Ring Road.

3.1 Unattended measurement data - traffic

Appendix C shows the monitoring locations, Appendix D provides further detail on the methodology, and measured traffic noise levels are summarised in Table 1.

Table 1: Measured traffic noise levels, dB

Description	Highest traffic noise level,	Average weekday traffic
	L _{10,18hr}	noise level, L _{10,18hr}
Location 1	59	58
Location 2	56	55
Location 3	58	57
Location 4	56	55
Location 5	55	53

Measured ambient noise levels are summarised in Table 2 and presented graphically in Appendices E-I.

Table 2: Highest measured ambient noise levels, dB

Description	Highest ambient noise level, L _{Aeq,15 mins}		
	Day	Evening	Night
Location 1	65	64	62
Location 2	69	71	60
Location 3	62	61	59
Location 4	65	57	57
Location 5	71	72	68

3.2 Unattended measurement data – rail

Consecutive measurements of rail traffic noise levels were obtained at the southern boundary of the site (Location 5) in order to compare with the Victorian Passenger Rail Infrastructure Noise policy (VPRINP) and are summarised in Table 3.

Table 3: Maximum and average rail noise levels, dB

Description	Night-time Average Noise Level, $L_{Aeq, 8hr}$	Maximum Noise Level, L_{Amax}		
		Day	Evening	Night
Location 5	62	93-100	90-100	80-100
95th percentile maximum of all night-time rail events				90

The above results show that the maximum noise levels from passing trains was 100 dB L_{Amax} , thus exceeding the VPRINP investigation thresholds residential uses near an existing rail corridor. 20 events above 85 dB L_{Amax} were measured during the night.

The VPRINP requires the assessment to be based on the 95th percentile of the maximum measured noise, which was 90 dB L_{Amax} during the night.

3.3 Weather conditions

It is noted that the graphical representations of the measured levels, given in Appendix E-I, show that a significant portion of the measurement period was affected by adverse atmospheric conditions. That is high wind or rain, based on BOM observations taken from Avalon Airport, the nearest weather station, which is approximately 34 km to the north of the site.

4.0 NOISE GUIDELINES

A range of guidelines and legislation is used in Victoria to assess and control environmental noise.

A summary of relevant guidelines referenced in Victorian noise assessments is presented in Table 4. Refer to Appendix J for further details.

Table 4: Relevant Victorian references and guidelines

Reference	Overview
<i>VicRoads' Traffic Noise Reduction Policy</i>	VicRoads has developed guidelines for noise mitigation at residential developments near major roads. Refer to Appendix J1 for further detail.
Australian/New Zealand Standard AS/NZS 2107:2016 " <i>Acoustics - Recommended design sound levels and reverberation times for building interiors</i> " (AS 2107)	Provides recommendations for acceptable internal noise levels. Table 1 of AS 2107 presents the recommended design sound levels for "houses and apartments in inner city areas or entertainment districts or near major roads", which is considered to be applicable to the development site. Refer to Appendix J2 for further detail.
<i>Victorian Passenger Rail Infrastructure Noise Policy</i> (VPRINP)	Released in April 2013. Section 5 of the policy sets out the conditions under which transport bodies must apply the policy. The policy sets 'investigation thresholds' for the assessment of noise. These are noise levels, which if exceeded, indicate that noise mitigation should be considered. Refer to Appendix J3 for further detail.
Sleep disturbance criteria sourced from NSW Road Noise Policy 2011 (Sleep disturbance criteria)	The provisions of this document are often referred to in Victoria for general guidance on potential sleep disturbance. Based on a review of research into sleep disturbance, the NSW policy nominates maximum internal night-time noise levels at noise sensitive locations which are unlikely to disturb sleep. Refer to Appendix J4 for further detail.

5.0 PRELIMINARY TRAFFIC NOISE ASSESSMENT

The following sections provide assessment against VicRoads policy and Australian Standard AS2107.

5.1 Traffic volumes

VicRoads typically require noise levels to be predicted based on the traffic volumes expected 10 years after the finalisation of the development. For the purposes of this assessment it has been assumed that that 'finalisation of the development' means the end of civil works, not construction of houses, therefore traffic conditions for 2029 have been estimated based on the latest available volumes (2015) and historical growth rates.

Table 5 provides a summary of the traffic information obtained from VicRoads' website.

Table 5: Traffic volumes (vehicles per day) and compositions obtained from VicRoads' website

		2006	2013	2014	2015	2016
Geelong Ring Road - North East Bound	All veh	4,400	5,000	5,200	5,300	5,400
	Trucks	720	810	860	850	840
	%HV	16	16	17	16	16
Geelong Ring Road - South West Bound	All veh	4,400	5,000	5,200	5,300	5,300
	Trucks	760	860	910	910	890
	%HV	17	17	18	17	17

These figures show an average growth 5% per annum from 2005 to 2016. Based on this growth rate, daily traffic volumes were calculated for 2028. The estimated volumes are shown in Table 6.

Table 6: Daily traffic volumes used in noise prediction

Carriageway	2016	2029
Geelong Ring Road - North East Bound	5,400	7,900
Geelong Ring Road - South West Bound	5,300	7,800

A traffic increase of this magnitude is estimated to raise the noise level at the west boundary of the site by less than 2 dB.

There is no data for Baanip Boulevard available on the VicRoads website. It has been assumed that this road will be subject to similar traffic flow increase as the Freeway.

5.1.1 Predicted traffic noise levels

Predicted noise levels have been based upon the measured traffic noise levels given in Table 8, the building layouts given in Appendix C and the traffic volumes detailed in Section 5.1.

VicRoads criteria for new residential developments adjacent to major roads is detailed in Appendix J2 and is applicable at ground floor level only.

The worst-case receptor to the west and south boundaries has been presented in Table 7.

Table 7: Predicted noise levels at ground floor level (2029), dB L_{A10(18h)}

	West boundary	South Boundary
Highest average weekday measured level	58	55
Facade correction	+2.5	+2.5
Estimated increase due to higher traffic volumes	+1.8	+1.8
Predicted noise level (2028)	62	59
VicRoads criteria	63	63
Compliance?	Yes	Yes

It can be seen that the predicted noise levels are within the VicRoads policy and it is considered therefore that no mitigation treatment is required under the terms of that policy.

However, it is considered appropriate to upgrade the construction of those facades which face the freeway such that compliance with AS2107 is achieved.

Example building facade constructions that would allow the AS2107 noise levels to be met inside the development are outlined in Section 7.

6.0 PRELIMINARY RAIL NOISE ASSESSMENT

The following sections provide assessment against the Victorian Passenger Rail Infrastructure Noise policy

6.1 Daily rail usage

Analysis of the timetable for the Geelong/Warrnambool line indicates that there are no scheduled passenger services during the night-time period on the section of line that passes the Hams Road site.

However, it is understood that this may change in the future, as advised by PTV:

As part of the Geelong to Waurn Ponds project, TfV are undertaking design work to determine the project scope to allow for trains to operate from Waurn Ponds Station every 10 minutes during the peak periods. This will likely involve track duplication from South Geelong to the proposed Waurn Ponds train stabling site. The future services that will operate along this corridor include 10 minute service to Waurn Ponds, 5 return services per day to Warrnambool.

In addition, freight services will also increase there is currently 1 freight train travelling in each direction daily, and this will increase to two train services travelling in each direction daily.

To assist with the rail assessment, it is necessary to estimate train pass-by frequency at the site. A review of the Vline timetable for the Warrnambool (Via Colac and Geelong) service and the Melbourne to Geelong service, which terminates at Waurn Ponds, indicates the following daily weekday activity.

Table 8: Average weekday train movements past the site

Period	VLine Passenger Diesel		
	Warrnambool (via Colac and Geelong)	Melbourne	Diesel Freight
Day (0700 – 2200 hrs)	7	0	
Night (2200 – 0700 hrs)	0	0	2*

* - the measured data suggests that there are 1-2 freight train pass-bys per day. The time at which the pass-by occurs on each day can vary significantly.

6.2 Maximum noise levels due to trains

The 95th percentile of the measured maximum rail noise levels during the night was 90 dB L_{Amax} .

Predicted internal noise levels comply with the sleep disturbance criteria, based on the measured external noise levels and the constructions detailed in Section 5.3.

Note that compliance with the sleep disturbance criteria will not be achieved with the doors or windows open.

6.3 Victorian Passenger Rail Infrastructure Noise Policy

Maximum noise levels at the nearest future dwelling due to train pass-bys indicate that the investigation thresholds set down in the *Victorian Passenger Rail Infrastructure Noise Policy* are exceeded since rail events were measured to be above the policy investigation of threshold of 85 dB L_{Amax} during the night-time period.

In addition, the highest measured average noise level during the night due to rail was 62 dB $L_{Aeq,8hr}$ which exceeds the policy investigation threshold of 60 dB $L_{Aeq,8h}$.

It is considered therefore that noise mitigation measures are required under the terms of that policy.

Section 7 of the *Victorian Passenger Rail Infrastructure Noise Policy* gives two alternative paths of investigation regarding the mitigation of railway noise.

“1) Options that would avoid exposure to rail noise of the receivers (for example, places where people sleep) through the way land is used, for example:

- a) specifying the types of land use in proximity to rail infrastructure*
- b) requiring set-back from the rail reserve*
- c) encouraging the location of non-sensitive receivers (for example, commercial uses) in proximity to the rail corridor.*

2) Options that would reduce or mitigate the exposure to rail noise of the receivers through building and architectural treatments, for example:

- a) requiring developers to consider building orientation, placement on site and design of floor plans*
- b) use of building materials including double-glazing that can help reduce or mitigate internal noise in a building.*

Note that options involving rail infrastructure design features are not applicable to a change in land use near an existing passenger rail corridor.”

6.4 Waurn Ponds train stabling facility

Publicly available information indicates that the proposed Waurn Ponds train stabling facility is likely to be located on land at 255 Reservoir Road in Mount Duneed at a distance of approximately three kilometres to the south west of the subject site. The location of land relative to the subject site is shown in Figure 3.

Figure 3: Stabling yard relative to the subject site



MDA considers that the introduction of the stabling yard, which is understood will be operational by 2019, will have no effect on the noise environment at the subject site due to the significant attenuation that would be provided by distance between the two sites.

Changes in noise level due to an increase in trains which will travel past the site to/from the stabling yard has been considered in Section 7.5.

7.0 RECOMMENDED CONSTRUCTIONS

Rail traffic noise exposure to the south boundary and road traffic noise to the east boundary of the development is considered to be high.

As is the case for any building that is exposed to significant external noise, the design criteria will not be achieved with windows open, however, the occupants have the option to close external windows and doors to significantly reduce noise intrusion.

Ventilation may be required in some rooms in order to allow the windows to remain closed. This should be addressed by the projects mechanical consultant.

In general, the glazing and facade construction requirements for facades with line of sight to the railway are driven by maximum internal levels due to train pass-bys, while those with line of sight to the Freeway are driven by average noise levels due to traffic.

It should be noted that the solid sections of the facade must be constructed of masonry or multiple layer materials as a lightweight facade will not provide sufficient noise insulation. Care should also be taken when specifying openings to the facade such as kitchen extract ducts or ventilation path ways to ensure that noise ingress through these does not undermine the noise insulation performance of the glazing and walls.

External sliding doors and openable windows must seal to a high standard.

Details of the proposed dwelling constructions are not available at this stage and therefore treatment for the proposed dwellings is based on a typical two storey construction.

Alternative constructions may be acceptable but should be reviewed by MDA prior to being documented.

7.1 Road traffic noise – Geelong Ring Road

From the concept plan, it is estimated that the nearest boundary of future dwellings at the western end of the site will be 50 m from the near side of Geelong Ring Road. The building facades will be set back from the boundary; however, the exact setback distance is unknown at this stage and therefore the assessment has been undertaken at the boundary.

7.1.1 VicRoads Policy

Noise levels due to road traffic at the nearest building facade to Geelong Ring Road in 2027 are likely to be in the region of 62 dB $L_{A10, 18hr}$. This is below the VicRoads policy noise level (refer Appendix K1) and it is considered therefore that no special treatment is required to the Geelong Ring Road boundary of the site.

7.1.2 AS2107

Noise levels due to road traffic are likely to be in the region of 62 - 65 dB $L_{Aeq, 15mins}$ during the daytime and 59 – 62 dB $L_{Aeq, 15mins}$ during the night.

Measured noise levels corrected for future traffic growth are 66 dB $L_{Aeq, 15min}$ for the daytime and 64 dB $L_{Aeq, 15mins}$ for the night.

As such, MDA recommends the following construction for buildings to the west end of the development with line of sight to the freeway:

- Facades with line of sight to the road: 9 mm compressed fibre cement sheet, 90 mm timber stud with insulation, 1 x 13 mm standard plasterboard
- Glazing to habitable rooms with line of sight to the road: 6.76 mm laminated glass
- Roof: metal deck with insulation and ceiling comprised of 1 x 10 mm standard plasterboard.

7.2 Road traffic noise – Baanip Boulevard

From the concept plan, it is estimated that the nearest boundary of future dwellings at the southern end of the site will be 40 m from the near side of Baanip Boulevard. The building facades will be set back from the boundary; however, the exact setback distance is unknown at this stage and therefore the assessment has been undertaken at the nearest lot boundary to the road.

7.2.1 VicRoads Policy

Noise levels due to road traffic at the nearest building facade to Baanip Boulevard are likely to be in the region of 59 dB $L_{A10, 18hr}$. This is below the VicRoads policy noise level (refer Appendix K1) and it is considered therefore that no special treatment is required to the Baanip Boulevard boundary of the site.

7.2.2 AS2107

The highest measured noise level due to road traffic was 65 dB $L_{Aeq, 15mins}$ during the daytime and 57 dB $L_{Aeq, 15mins}$ during the night.

Measured noise levels corrected for future traffic growth are 66 dB $L_{Aeq, 15min}$ for the daytime and 59 dB $L_{Aeq, 15mins}$ for the night.

As such, MDA recommends the following construction for buildings to the south side of the development with line of sight to the road, note that more stringent constructions apply to those lots directly adjacent to the railway, as discussed in Section 7.5:

- Facades with line of sight to the road: 6 mm compressed fibre cement sheet, 90 mm timber stud with insulation, 1 x 10 mm standard plasterboard
- Glazing to habitable rooms with line of sight to the road: 6.76 mm laminated glass
- Roof: metal deck with insulation and ceiling comprised of 1 x 10 mm standard plasterboard.

7.3 Road traffic noise – Hams Road

No special treatment is required to residences facing Hams Road in order to meet the internal noise level criteria of AS2107.

However, it should be noted that some lots to the west will have line of sight to the freeway and future dwellings should therefore be constructed in accordance with Section 7.1.2.

7.4 Road traffic noise – Ghazeepore Road

MDA measured traffic noise on Ghazeepore road in 2013 (refer MDA report Rp001 R04 2013193ML, dated 10 June 2014). At that time, the concept plan showed future dwellings at the eastern end of the site that were adjacent to the kerb of Ghazeepore Road.

In the interim, it is understood that the parcel of land between the existing Powercor substation in the north east corner of the site and the railway to the south will be utilised as a retarding basin (RB2 on the concept plan). As such, the boundary of lots to the east end of the site will now be set back from Ghazeepore road by approximately 100 m.

Note that the south, west and east facades of the nearest dwellings to RB2 will also have an interface with the railway and as such are addressed in Section 7.5.

7.5 Railway noise

From the concept plan, it is estimated that the boundary of future dwellings at the southern end of the site will be 25 m from the near side rail of the railway. The building facades will be set back from the boundary; however, the exact setback distance is unknown at this stage and therefore the assessment has been undertaken at the boundary. The measured noise levels have been taken as being representative of the likely noise exposure of a building located 25 m from the near side rail.

Details of the proposed dwellings are not available at this stage. Therefore, the following acoustic treatment is based on meeting the internal noise criteria for a typical two storey construction for lots within 100 m of the railway that have direct line of sight to it:

- Facades with line of sight to the railway: 110 mm brick, 90 mm timber stud with insulation, 1 x 10 mm standard plasterboard
- Glazing to habitable rooms with line of sight to the railway: 6/12/10.76 mm laminated glass
- Roof: metal deck with insulation and ceiling comprised of 2 x 10 mm standard plasterboard.

It has been assumed that the preference would be to upgrade the facades of dwellings instead of altering the layout of the subdivision or installing a noise barrier, however the following alternate solutions could be considered in lieu of facade upgrades:

- Orient dwellings on the boundary with the railway such that they act as a noise barrier. This would mean that the buildings would form a continuous line along the boundary and those facades facing the railway would be blank. Operable windows could be acceptable if they were within a light court which was not operable; or
- Install a noise barrier to the full extent of the southern boundary.

This section of track is part of the main interstate line from Melbourne to Adelaide and as such sees regular freight traffic.

The *Victorian Passenger Rail Infrastructure Noise Policy* does not apply to freight services, and therefore the internal noise criteria detailed in Appendix J is considered to be applicable.

The maximum noise level due to a freight train pass-by has been measured as 100 dB L_{Amax} during the night. It is considered that the recommendations for acoustic treatment to mitigate noise from passenger services, as discussed above, should be sufficient to mitigate noise from freight services.

It is noted that the frequency of both passenger and freight traffic past the site is set to increase in the future. However, the facade constructions detailed above are driven by the maximum noise level (dB L_{Amax}) which is not affected by the number of trains. Notwithstanding this, the NSW policy notes that from the research on sleep disturbance to date it can be concluded that:

- *maximum internal noise levels below 50–55 dB L_{Amax} are unlikely to awaken people from sleep*
- *one or two noise events per night, with maximum internal noise levels of 65–70 dB L_{Amax} , are not likely to affect health and wellbeing significantly.*

Therefore, an increase in the number of freight train pass-bys from two per day to four (as advised by PTV) is unlikely to alter the outcome of the assessment.

7.6 Notes on building constructions

The following points should be considered with respect to the recommended building constructions detailed herein:

- Should the builders select alternative windows for thermal insulation, care shall be taken such that the acoustic performance of such system meets the minimum sound transmission loss requirements. The final glazing selection will be dependent on size, function, and relevant Australian Design Standards. This assessment considers a typical of room size with total glazing areas of up to 8 m² per room at ground level and 3 m² at first floor level.
- For this assessment, split system air-conditioning systems have been assumed in preference to the more acoustically open evaporative type air conditioning systems. Ventilation paths may be required to be acoustically treated to control noise break-in and ensure that the sound insulation performance of the building envelope is not compromised. Suitable ventilation may include a ducted system with internal lining, an acoustically rated trickle vent system such as a Silenceair or Titon Trimvent system or an approved equivalent.

8.0 CONCLUSION

Taylor's Development Strategists Pty Ltd, on behalf of Echin Pty Ltd and Waurin Ponds Unit Trust C/o Urban Quarter WA, are working on the development of land for residential use at 35 and 69 - 93 Hams Road in Waurin Ponds. Marshall Day Acoustics (MDA) has been requested to provide acoustic input to secure a planning permit for approximately 270 residential lots that abut Baanip Boulevard to the south and Geelong Ring Road to the west.

As part of the development, Marshall Day Acoustics Pty Ltd (MDA) has been commissioned to undertake a noise assessment to consider traffic and train noise intrusion to future dwellings.

MDA has carried out environmental noise assessment of the proposed development in accordance with the relevant Victorian EPA legislation, guidelines and accepted industry practice.

This assessment has been based on:

- Existing noise conditions determined from a measurement surveys at the site; and
- Criteria determined in accordance with the relevant Victorian guidelines and accepted industry practice.

It is considered that appropriate acoustic treatment can be implemented in the design in order to comply with the applicable noise criteria.

No noise mitigation measures are required in order to meet VicRoads policy to properties adjacent to Geelong Ring Road, Baanip Boulevard, Ghazeeopore Road or Hams Road. However, the facade and glazing of dwellings with line of sight to each will need to be upgraded, and reviewed by a suitably qualified acoustic consultant at the detailed design stage, in order to achieve the requirements of AS2107 for sleeping and living areas.


Measured rail noise levels have been assessed according to the *Victorian Passenger Rail Infrastructure Policy*. Existing maximum noise levels at the nearest proposed facades are likely to exceed the Policy threshold of 85dB L_{Amax} .

Therefore, specific acoustic treatments will be required to future properties along the southern boundary of the development site in order to control railway noise. Such treatments will need to be selected in consultation with a suitably qualified acoustic engineer at the detailed design stage.

APPENDIX A GLOSSARY OF TERMINOLOGY

dB	<u>Decibel</u> The unit of sound level.
Ambient	The ambient noise level is the noise level measured in the absence of the intrusive noise or the noise requiring control. Ambient noise levels are frequently measured to determine the situation prior to the addition of a new noise source.
A-weighting	The process by which noise levels are corrected to account for the frequency response of the human ear.
Octave Band	A range of frequencies where the highest frequency included is twice the lowest frequency. Octave bands are referred to by their logarithmic centre frequencies, these being 31.5 Hz, 63 Hz, 125 Hz, 250 Hz, 500 Hz, 1 kHz, 2 kHz, 4 kHz, 8 kHz, and 16 kHz for the audible range of sound.
$L_{Aeq, 15mins}$	The equivalent continuous (time-averaged) A-weighted sound level. This is commonly referred to as the average noise level over 15 minutes.
$L_{A10}(t)$	The A-weighted noise level equalled or exceeded for 10% of the measurement period. This is commonly referred to as the average maximum noise level. The suffix "t" represents the time period to which the noise level relates, e.g. (8 h) would represent a period of 8 hours, (15 min) would represent a period of 15 minutes and (2200-0700) would represent a measurement time between 10 pm and 7 am.
Sound Insulation	When sound hits a surface, some of the sound energy travels through the material. 'Sound insulation' refers to ability of a material to stop sound travelling through it.
R_w	<u>Weighted Sound Reduction Index</u> A single number rating of the sound insulation performance of a specific building element. R_w is measured in a laboratory. R_w is commonly used by manufacturers to describe the sound insulation performance of building elements such as plasterboard and concrete.

APPENDIX B INDICATIVE SITE LAYOUT PLAN



APPENDIX C UNATTENDED NOISE MONITORING LOCATIONS



APPENDIX D UNATTENDED NOISE MONITORING METHODOLOGY

Traffic and train noise levels at the site were measured using five Rion NL-31 precision integrating sound level meters fitted with windshields.

The microphones were mounted on tripods at a height of approximately 1.5 m above local ground level under freefield conditions.

Measurements were obtained using the 'F' response time and A-weighting frequency network. The equipment was checked before and after the survey and no significant calibration drifts were observed.

Consecutive measurements were obtained between 1400 hrs on Tuesday 30th January and 1200 hrs on Friday 9th February 2018.

Weather data has been taken from the Bureau of Meteorology's weather station at Avalon Airport, periods of high wind or significant rainfall have been highlighted in Appendix E to Appendix I. It should be noted that the measurements presented in the graphs have been calculated into 30-minute periods for the purposes of comparison with the weather data.

Figures 4 – 8 provide views of the monitoring locations.

Figure 4: Unattended noise monitor – Location 1



Figure 5: Unattended noise monitor – Location 2



Figure 6: Unattended noise monitor – Location 3



Figure 7: Unattended noise monitor – Location 4



Figure 8: Unattended noise monitor – Location 5



Tables 9 - 11 provide a summary of the measured noise levels.

Table 9: Measured road traffic noise levels

Period	Road Traffic Noise Level, LA10 (18 h) dB				
	Location 1	Location 2	Location 3	Location 4	Location 5
Tuesday, 30 Jan 2018	_*	_*	_*	_*	_*
Wednesday, 31 Jan 2018	59	56	57	56	55
Thursday, 01 Feb 2018	58	55	57	54	54
Friday, 02 Feb 2018	59	55	58	56	54
Saturday, 03 Feb 2018	55	53	57	54	53
Sunday, 04 Feb 2018	54	52	55	53	54
Monday, 05 Feb 2018	58	56	56	53	52
Tuesday, 06 Feb 2018	57	56	57	54	52
Wednesday, 07 Feb 2018	57	55	57	54	50
Thursday, 08 Feb 2018	58	55	57	55	52
Friday, 09 Feb 2018	_*	_*	_*	_*	_*
Average on weekdays	58	55	57	55	53

* - Incomplete period


Table 10: Measured ambient noise levels – Night time

Period	Highest Ambient Noise Level, LAeq,15mins dB				
	Location 1	Location 2	Location 3	Location 4	Location 5
Tuesday, 30 Jan 2018	61	58	57	55	66
Wednesday, 31 Jan 2018	58	55	57	55	64
Thursday, 01 Feb 2018	59	56	58	53	66
Friday, 02 Feb 2018	55	50	53	52	68
Saturday, 03 Feb 2018	60	51	54	53	66
Sunday, 04 Feb 2018	61	57	58	57	63
Monday, 05 Feb 2018	61	57	59	55	68
Tuesday, 06 Feb 2018	62	60	58	54	67
Wednesday, 07 Feb 2018	60	60	58	55	65
Thursday, 08 Feb 2018	57	55	58	55	66
Friday, 09 Feb 2018	-	-	-	-	-
Maximum	62	60	59	55	68


Table 11: Measured maximum noise levels – Night time

Period	Highest Noise Level, L _{Amax} dB				
	Location 1	Location 2	Location 3	Location 4	Location 5
Tuesday, 30 Jan 2018	77	72	72	71	94
Wednesday, 31 Jan 2018	79	69	74	74	89
Thursday, 01 Feb 2018	78	74	77	67	90
Friday, 02 Feb 2018	77	71	78	76	99
Saturday, 03 Feb 2018	79	70	70	78	88
Sunday, 04 Feb 2018	77	73	79	75	80
Monday, 05 Feb 2018	75	76	79	77	100
Tuesday, 06 Feb 2018	78	76	77	74	100
Wednesday, 07 Feb 2018	76	77	72	69	92
Thursday, 08 Feb 2018	73	72	74	74	96
Friday, 09 Feb 2018	-	-	-	-	-
Maximum	79	76	79	77	100


APPENDIX E UNATTENDED NOISE MONITORING RESULTS – LOCATION 1




APPENDIX F UNATTENDED NOISE MONITORING RESULTS – LOCATION 2




APPENDIX G UNATTENDED NOISE MONITORING RESULTS – LOCATION 3



APPENDIX H UNATTENDED NOISE MONITORING RESULTS – LOCATION 4



APPENDIX I UNATTENDED NOISE MONITORING RESULTS – LOCATION 5



APPENDIX J NOISE GUIDELINES

J1 Road Traffic Noise

VicRoads' *Traffic Noise Reduction Policy* recommends traffic noise level objectives that are used by VicRoads when building new roads or upgrading existing roads. In addition, VicRoads has developed guidelines for noise mitigation at residential developments near major roads. These guidelines recommend developers undertake some combination of the following:

- Erect traffic noise barriers of sufficient height and suitable construction in order to reduce external noise levels to 63 dB $L_{A10(18h)}$ or less at the worst-affected dwellings
- Provide sound insulation treatment to residential dwellings sufficient to achieve compliance with the recommended internal noise levels specified in Australian Standard 2107-2016 *Acoustics - Recommended design sound levels and reverberation times for building interiors*.

J2 Environmental noise

Australian Standard 2107-2016 *Acoustics - Recommended design sound levels and reverberation times for building interiors* provides recommendations for acceptable internal noise levels. Table 9 shows the recommended internal design sound levels stated in AS2107 for "houses and apartments in inner city areas or entertainment districts or near major roads", which is considered to be applicable to the proposed development.

Table 12: AS2107 recommended internal noise levels

Area	Recommended design sound level range, dB L_{Aeq}
Living areas	35-45
Sleeping areas	35-40
Work areas	35-45
Apartment common areas (e.g. lobbies)	45-50

Compliance with the lower level is preferred, but compliance with the maximum noise level is considered to be acceptable.

AS2107 does not specify the measurement procedure to determine whether compliance has been achieved but does state the following:

In situations where traffic (or other) noise levels may vary widely over a 24-hour period, measurements to assess compliance with this Standard should be taken at the relevant time according to the area of occupancy or activity in the building.

Given the above, it could be argued that compliance measurements for bedrooms should be made during the period between 2200-0700 hrs (commonly referred to as the night period), although this does not allow for those occupants who may be shift workers or such like that may have a requirement to sleep during the day. For living and dining rooms, the compliance measurement should be made during the period between 0700-2200 hrs (commonly referred to as the day/evening period).

Further, AS2107 does not specify the noise measurement duration. It is recommended that compliance generally be assessed based on the typical worst-case 15-minute L_{Aeq} noise level throughout the relevant time period (e.g. night-time for bedrooms).

Higher quality developments should obviously aim to achieve lower levels of traffic noise intrusion. MDA's project experience shows that if internal noise levels in bedrooms or living areas exceed an hourly average of approximately 40 dB L_{Aeq} that the level of occupant dissatisfaction is likely to be relatively high.

An internal level of 35 dB L_{Aeq} within bedrooms at night has been selected in this case.

J3 Railway noise

The *Victorian Passenger Rail Infrastructure Noise Policy* was released in April 2013. Section 5 of the policy sets out the conditions under which transport bodies must apply the policy.

The policy sets ‘investigation thresholds’ for the assessment of noise. These are noise levels, which if exceeded, indicate that noise mitigation should be considered. It states that:

In considering changing land use near an existing passenger rail corridor, transport bodies and planning authorities should consider the receivers set out in Table B in Attachment 2. Transport bodies and planning authorities should consider whether the noise level produced at these receivers will exceed the investigation thresholds for the periods specified in Table B in Attachment 2. [Table B of Attachment 2 is reproduced below as Table 13 in this report.]

If an assessment shows the investigation thresholds are not exceeded, noise impacts should be considered a secondary matter. This means no further action need be considered under this policy.

The investigation thresholds are defined in terms of:

- $L_{Aeq,16h}$ – equivalent continuous daytime (0600-2200) noise level
- $L_{Aeq,8h}$ – equivalent continuous night-time (2200-0600) noise level
- L_{Amax} – maximum noise level.

Investigation thresholds for the redevelopment of land near existing rail infrastructure are presented in Table 13.

Table 13: Investigation thresholds for changing allowable land use near an existing rail corridor

Time	Type of receiver	Investigation thresholds		
Daytime (0600-2200)	Residential dwellings including aged person homes, hospitals, motels, caravan parks, and other buildings where people sleep.	65 dB $L_{Aeq,16h}$	or	85 dB L_{Amax}
	Noise sensitive community buildings including schools, kindergartens, libraries			
Night-time (2200-0600)	Residential dwellings including aged person homes, hospitals, motels, caravan parks, and other buildings where people sleep.	60 dB $L_{Aeq,8h}$	or	85 dB L_{Amax}

The investigation thresholds are not design criteria. However, should the investigation thresholds be exceeded, then the following internal design criteria are recommended for residences adjacent to the Geelong/Warrnambool railway:

- Bedrooms: 55 dB L_{Amax}
- Other living areas: 60 dB L_{Amax}

These limits are based on a precedent set in the Victorian Civil and Administrative Tribunal (VCAT) regarding acceptable internal noise levels for residences adjacent to railway lines (Reference No. P2470/2003). In this case, a decision to grant a permit was made on the basis that the noise level of trains was not to exceed 55 dB L_{Amax} in bedrooms and 60 dB L_{Amax} in living areas.

J4 Sleep Disturbance

The NSW Road Noise Policy 2011 produced by the NSW EPA, provides guidance on potential for sleep disturbance. While the Policy applies strictly only in NSW, the provisions of the document are often referred to in Victoria for general guidance on potential sleep disturbance.

The NSW policy notes that from the research on sleep disturbance to date it can be concluded that:

- *maximum internal noise levels below 50–55 dB L_{Amax} are unlikely to awaken people from sleep*
- *one or two noise events per night, with maximum internal noise levels of 65–70 dB L_{Amax} , are not likely to affect health and wellbeing significantly.*

Since 2003, there have been two VCAT decisions which have recommended an internal noise limit of 50 dB L_{Amax} in bedrooms. However, there is no compelling case for the lower criterion as the decisions were not based on objective evidence presented to the Tribunal and are, in our opinion, unnecessarily restrictive. 55dB L_{Amax} is very close to the threshold of onset for noise-related sleep disturbance, and there is almost no significant difference (<1%) in reported levels of sleep disturbance between 55 dB L_{Amax} and 50 dB L_{Amax} .

These criteria (55 dB L_{Amax}) has now been accepted by Public Transport Victoria (PTV) in a letter dated 18 October 2012, in relation to a residential development in Braybrook. Further details can be provided if requested.

APPENDIX K NOISE AND WEATHER DATA

Date	Time	Ambient noise level dB LAeq, 30mins					BOM weather data (Geelong Airport)		
		Location 1	Location 2	Location 3	Location 4	Location 5	Wind (m/s)	Rain (mm)	Data acceptability
Tuesday, 30 January 2018	13:00						9	0	Unacceptable
Tuesday, 30 January 2018	13:30	59	56				9	0	Unacceptable
Tuesday, 30 January 2018	14:00	60	57	57			8	0	Unacceptable
Tuesday, 30 January 2018	14:30	60	57	57	56		8	0	Unacceptable
Tuesday, 30 January 2018	15:00	60	57	56	55	55	8	0	Unacceptable
Tuesday, 30 January 2018	15:30	60	56	56	55	53	9	0	Unacceptable
Tuesday, 30 January 2018	16:00	60	57	57	56	52	8	0	Unacceptable
Tuesday, 30 January 2018	16:30	60	57	57	55	54	8	0	Unacceptable
Tuesday, 30 January 2018	17:00	60	57	56	55	52	8	0	Unacceptable
Tuesday, 30 January 2018	17:30	59	56	56	55	51	8	0	Unacceptable
Tuesday, 30 January 2018	18:00	58	55	55	54	52	8	0	Unacceptable
Tuesday, 30 January 2018	18:30	59	55	55	55	62	8	0	Unacceptable
Tuesday, 30 January 2018	19:00	57	54	53	52	57	8	0	Unacceptable
Tuesday, 30 January 2018	19:30	56	54	53	53	53	7	0	Unacceptable
Tuesday, 30 January 2018	20:00	56	52	51	51	69	7	0	Unacceptable
Tuesday, 30 January 2018	20:30	59	54	51	51	62	7	0	Unacceptable
Tuesday, 30 January 2018	21:00	55	51	49	47	52	5	0	Unacceptable
Tuesday, 30 January 2018	21:30	53	50	49	47	60	4	0	Unacceptable
Tuesday, 30 January 2018	22:00	53	49	47	47	64	5	0	Unacceptable
Tuesday, 30 January 2018	22:30	49	47	45	44	54	4	0	Unacceptable
Tuesday, 30 January 2018	23:00	51	48	47	44	52	5	0	Unacceptable
Tuesday, 30 January 2018	23:30	53	51	48	45	48	3	0	Acceptable
Tuesday, 30 January 2018	0:00	51	48	47	44	48	3	0	Unacceptable
Wednesday, 31 January 2018	0:30	51	48	45	43	45	3	0	Acceptable
Wednesday, 31 January 2018	1:00	52	49	46	43	42	3	0	Unacceptable
Wednesday, 31 January 2018	1:30	48	46	44	40	40	3	0	Unacceptable
Wednesday, 31 January 2018	2:00	51	47	44	42	46	3	0	Unacceptable
Wednesday, 31 January 2018	2:30	48	46	44	43	44	2	0	Acceptable
Wednesday, 31 January 2018	3:00	52	49	45	43	44	4	0	Unacceptable
Wednesday, 31 January 2018	3:30	52	49	46	44	42	5	0	Unacceptable
Wednesday, 31 January 2018	4:00	52	49	46	44	42	3	0	Unacceptable
Wednesday, 31 January 2018	4:30	54	50	49	49	44	4	0	Unacceptable
Wednesday, 31 January 2018	5:00	56	53	51	49	62	3	0	Acceptable
Wednesday, 31 January 2018	5:30	57	54	53	51	48	3	0	Acceptable
Wednesday, 31 January 2018	6:00	59	56	55	53	57	3	0	Unacceptable
Wednesday, 31 January 2018	6:30	61	58	56	54	63	5	0	Unacceptable
Wednesday, 31 January 2018	7:00	61	58	57	57	59	4	0	Unacceptable
Wednesday, 31 January 2018	7:30	61	59	57	56	52	3	0	Unacceptable
Wednesday, 31 January 2018	8:00	60	57	56	55	63	4	0	Unacceptable
Wednesday, 31 January 2018	8:30	59	56	55	53	51	3	0	Unacceptable
Wednesday, 31 January 2018	9:00	59	56	56	55	63	4	0	Unacceptable
Wednesday, 31 January 2018	9:30	59	56	55	55	52	8	0	Unacceptable
Wednesday, 31 January 2018	10:00	57	54	55	54	51	6	0	Unacceptable
Wednesday, 31 January 2018	10:30	58	56	56	55	51	6	0	Unacceptable
Wednesday, 31 January 2018	11:00	58	55	56	55	52	8	0	Unacceptable
Wednesday, 31 January 2018	11:30	58	56	58	57	65	9	0	Unacceptable
Wednesday, 31 January 2018	12:00	58	56	57	56	54	8	0	Unacceptable
Wednesday, 31 January 2018	12:30	57	54	56	54	53	9	0	Unacceptable
Wednesday, 31 January 2018	13:00	57	54	56	55	53	9	0	Unacceptable
Wednesday, 31 January 2018	13:30	56	54	56	55	52	8	0	Unacceptable
Wednesday, 31 January 2018	14:00	57	55	56	57	66	9	0	Unacceptable
Wednesday, 31 January 2018	14:30	57	55	56	55	60	7	0	Unacceptable
Wednesday, 31 January 2018	15:00	56	55	57	56	52	8	0	Unacceptable
Wednesday, 31 January 2018	15:30	57	55	57	56	52	8	0	Unacceptable
Wednesday, 31 January 2018	16:00	56	55	57	56	52	8	0	Unacceptable
Wednesday, 31 January 2018	16:30	56	54	56	54	52	8	0	Unacceptable

Date	Time	Ambient noise level dB L _{Aeq, 30mins}					BOM weather data (Geelong Airport)		
		Location 1	Location 2	Location 3	Location 4	Location 5	Wind (m/s)	Rain (mm)	Data acceptability
Wednesday, 31 January 2018	17:00	57	54	56	55	52	8	0	Unacceptable
Wednesday, 31 January 2018	17:30	57	54	56	55	52	8	0	Unacceptable
Wednesday, 31 January 2018	18:00	56	53	55	53	51	7	0	Unacceptable
Wednesday, 31 January 2018	18:30	56	53	54	53	63	6	0	Unacceptable
Wednesday, 31 January 2018	19:00	55	52	53	51	60	7	0	Unacceptable
Wednesday, 31 January 2018	19:30	54	50	52	51	57	6	0	Unacceptable
Wednesday, 31 January 2018	20:00	54	53	53	54	58	6	0	Unacceptable
Wednesday, 31 January 2018	20:30	57	50	52	51	65	5	0	Unacceptable
Wednesday, 31 January 2018	21:00	53	51	51	49	62	5	0	Unacceptable
Wednesday, 31 January 2018	21:30	51	48	49	48	60	5	0	Unacceptable
Wednesday, 31 January 2018	22:00	51	49	49	47	57	4	0	Unacceptable
Wednesday, 31 January 2018	22:30	51	49	49	49	49	5	0	Unacceptable
Wednesday, 31 January 2018	23:00	49	46	47	45	61	5	0	Unacceptable
Wednesday, 31 January 2018	23:30	49	46	47	45	45	5	0	Unacceptable
Wednesday, 31 January 2018	0:00	48	44	45	41	41	6	0	Unacceptable
Thursday, 1 February 2018	0:30	49	46	46	42	43	5	0	Unacceptable
Thursday, 1 February 2018	1:00	50	46	44	41	38	5	0	Unacceptable
Thursday, 1 February 2018	1:30	48	44	43	39	36	4	0	Unacceptable
Thursday, 1 February 2018	2:00	48	44	43	40	36	5	0	Unacceptable
Thursday, 1 February 2018	2:30	45	42	42	36	35	5	0	Unacceptable
Thursday, 1 February 2018	3:00	52	48	46	43	39	4	0	Unacceptable
Thursday, 1 February 2018	3:30	51	47	46	41	41	4	0	Unacceptable
Thursday, 1 February 2018	4:00	51	46	47	45	41	5	0	Unacceptable
Thursday, 1 February 2018	4:30	51	47	50	49	42	4	0	Unacceptable
Thursday, 1 February 2018	5:00	53	50	52	49	59	4	0	Unacceptable
Thursday, 1 February 2018	5:30	54	51	53	51	46	1	0	Acceptable
Thursday, 1 February 2018	6:00	56	54	56	54	57	1	0	Acceptable
Thursday, 1 February 2018	6:30	57	54	57	54	59	0	0	Acceptable
Thursday, 1 February 2018	7:00	56	53	56	52	55	1	0	Acceptable
Thursday, 1 February 2018	7:30	56	55	57	53	48	1	0	Acceptable
Thursday, 1 February 2018	8:00	56	55	57	54	63	1	0	Acceptable
Thursday, 1 February 2018	8:30	55	54	56	52	61	2	0	Acceptable
Thursday, 1 February 2018	9:00	55	54	57	51	55	3	0	Unacceptable
Thursday, 1 February 2018	9:30	55	54	55	51	48	1	0	Acceptable
Thursday, 1 February 2018	10:00	55	53	54	50	47	2	0	Acceptable
Thursday, 1 February 2018	10:30	56	54	57	53	49	2	0	Acceptable
Thursday, 1 February 2018	11:00	55	54	55	52	50	3	0	Acceptable
Thursday, 1 February 2018	11:30	57	55	57	55	68	5	0	Unacceptable
Thursday, 1 February 2018	12:00	56	54	56	54	50	6	0	Unacceptable
Thursday, 1 February 2018	12:30	54	52	54	53	50	6	0	Unacceptable
Thursday, 1 February 2018	13:00	55	53	55	53	50	7	0	Unacceptable
Thursday, 1 February 2018	13:30	55	53	55	54	50	7	0	Unacceptable
Thursday, 1 February 2018	14:00	56	54	56	55	65	7	0	Unacceptable
Thursday, 1 February 2018	14:30	55	53	56	53	59	7	0	Unacceptable
Thursday, 1 February 2018	15:00	54	52	55	53	50	7	0	Unacceptable
Thursday, 1 February 2018	15:30	56	53	56	54	51	7	0	Unacceptable
Thursday, 1 February 2018	16:00	56	53	56	54	51	6	0	Unacceptable
Thursday, 1 February 2018	16:30	56	54	56	54	51	6	0	Unacceptable
Thursday, 1 February 2018	17:00	56	54	56	54	50	7	0	Unacceptable
Thursday, 1 February 2018	17:30	57	54	55	54	51	6	0	Unacceptable
Thursday, 1 February 2018	18:00	56	53	55	54	50	7	0	Unacceptable
Thursday, 1 February 2018	18:30	56	54	54	53	64	6	0	Unacceptable
Thursday, 1 February 2018	19:00	55	52	53	52	60	8	0	Unacceptable
Thursday, 1 February 2018	19:30	56	52	53	53	60	7	0	Unacceptable
Thursday, 1 February 2018	20:00	55	53	53	51	66	6	0	Unacceptable
Thursday, 1 February 2018	20:30	61	53	53	53	63	5	0	Unacceptable
Thursday, 1 February 2018	21:00	53	50	50	49	57	5	0	Unacceptable

Date	Time	Ambient noise level dB L _{Aeq, 30mins}					BOM weather data (Geelong Airport)		
		Location 1	Location 2	Location 3	Location 4	Location 5	Wind (m/s)	Rain (mm)	Data acceptability
Thursday, 1 February 2018	21:30	53	50	50	47	57	4	0	Unacceptable
Thursday, 1 February 2018	22:00	52	49	48	46	61	5	0	Unacceptable
Thursday, 1 February 2018	22:30	51	47	47	43	53	4	0	Unacceptable
Thursday, 1 February 2018	23:00	50	46	47	44	47	4	0	Unacceptable
Thursday, 1 February 2018	23:30	52	48	47	44	42	3	0	Unacceptable
Thursday, 1 February 2018	0:00	50	46	46	41	50	4	0	Unacceptable
Friday, 2 February 2018	0:30	49	44	44	40	46	3	0	Unacceptable
Friday, 2 February 2018	1:00	52	49	47	43	44	3	0	Unacceptable
Friday, 2 February 2018	1:30	47	42	41	39	37	3	0	Acceptable
Friday, 2 February 2018	2:00	48	44	44	40	38	3	0	Unacceptable
Friday, 2 February 2018	2:30	47	44	42	36	37	3	0	Acceptable
Friday, 2 February 2018	3:00	51	47	44	39	37	3	0	Unacceptable
Friday, 2 February 2018	3:30	49	45	46	43	38	3	0	Acceptable
Friday, 2 February 2018	4:00	52	48	47	45	58	2	0	Acceptable
Friday, 2 February 2018	4:30	52	47	46	41	43	3	0	Unacceptable
Friday, 2 February 2018	5:00	54	50	50	45	44	3	0	Unacceptable
Friday, 2 February 2018	5:30	56	52	53	50	46	2	0	Acceptable
Friday, 2 February 2018	6:00	56	53	55	51	55	3	0	Acceptable
Friday, 2 February 2018	6:30	59	56	57	53	63	3	0	Acceptable
Friday, 2 February 2018	7:00	58	55	57	55	58	2	0	Acceptable
Friday, 2 February 2018	7:30	59	56	57	54	52	3	0	Unacceptable
Friday, 2 February 2018	8:00	59	56	56	55	63	4	0	Unacceptable
Friday, 2 February 2018	8:30	58	56	58	56	52	4	0	Unacceptable
Friday, 2 February 2018	9:00	57	54	56	54	63	4	0	Unacceptable
Friday, 2 February 2018	9:30	58	58	57	56	51	5	0	Unacceptable
Friday, 2 February 2018	10:00	60	55	56	53	51	4	0	Unacceptable
Friday, 2 February 2018	10:30	56	53	56	53	49	4	0	Unacceptable
Friday, 2 February 2018	11:00	56	55	55	56	50	4	0	Unacceptable
Friday, 2 February 2018	11:30	55	53	56	54	66	4	0	Unacceptable
Friday, 2 February 2018	12:00	55	53	55	54	49	5	0	Unacceptable
Friday, 2 February 2018	12:30	54	54	56	55	49	5	0	Unacceptable
Friday, 2 February 2018	13:00	54	53	55	53	50	5	0	Unacceptable
Friday, 2 February 2018	13:30	54	52	55	54	49	5	0	Unacceptable
Friday, 2 February 2018	14:00	56	53	54	55	65	6	0	Unacceptable
Friday, 2 February 2018	14:30	56	54	56	53	61	6	0	Unacceptable
Friday, 2 February 2018	15:00	57	54	56	54	51	6	0	Unacceptable
Friday, 2 February 2018	15:30	57	54	56	54	51	6	0	Unacceptable
Friday, 2 February 2018	16:00	57	54	57	55	52	6	0	Unacceptable
Friday, 2 February 2018	16:30	57	54	57	55	51	7	0	Unacceptable
Friday, 2 February 2018	17:00	57	54	56	54	52	8	0	Unacceptable
Friday, 2 February 2018	17:30	58	55	57	54	51	7	0	Unacceptable
Friday, 2 February 2018	18:00	57	54	57	55	51	7	0	Unacceptable
Friday, 2 February 2018	18:30	57	54	55	55	63	7	0	Unacceptable
Friday, 2 February 2018	19:00	56	53	54	52	57	7	0	Unacceptable
Friday, 2 February 2018	19:30	56	52	54	53	59	6	0	Unacceptable
Friday, 2 February 2018	20:00	58	53	53	50	65	6	0	Unacceptable
Friday, 2 February 2018	20:30	62	56	53	51	63	6	0	Unacceptable
Friday, 2 February 2018	21:00	55	51	53	51	59	4	0	Unacceptable
Friday, 2 February 2018	21:30	55	52	54	49	52	4	0	Unacceptable
Friday, 2 February 2018	22:00	54	52	53	51	65	3	0	Acceptable
Friday, 2 February 2018	22:30	51	48	50	48	50	4	0	Unacceptable
Friday, 2 February 2018	23:00	51	49	50	46	49	4	0	Unacceptable
Friday, 2 February 2018	23:30	49	46	48	45	53	4	0	Unacceptable
Friday, 2 February 2018	0:00	49	46	50	45	52	3	0	Unacceptable
Saturday, 3 February 2018	0:30	50	49	49	44	49	3	0	Unacceptable
Saturday, 3 February 2018	1:00	48	45	47	43	50	3	0	Unacceptable
Saturday, 3 February 2018	1:30	50	47	48	40	47	3	0	Acceptable
Saturday, 3 February 2018	2:00	48	43	45	41	49	2	0	Acceptable

Date	Time	Ambient noise level dB L _{Aeq, 30mins}					BOM weather data (Geelong Airport)		
		Location 1	Location 2	Location 3	Location 4	Location 5	Wind (m/s)	Rain (mm)	Data acceptability
Saturday, 3 February 2018	2:30	46	46	48	41	44	2	0	Acceptable
Saturday, 3 February 2018	3:00	48	44	45	41	45	3	0	Acceptable
Saturday, 3 February 2018	3:30	47	44	50	49	40	3	0	Acceptable
Saturday, 3 February 2018	4:00	49	48	45	40	63	3	0	Acceptable
Saturday, 3 February 2018	4:30	46	43	48	44	40	2	0	Acceptable
Saturday, 3 February 2018	5:00	49	48	49	45	41	3	0	Unacceptable
Saturday, 3 February 2018	5:30	49	47	50	46	44	4	0	Unacceptable
Saturday, 3 February 2018	6:00	51	49	53	49	45	4	0	Unacceptable
Saturday, 3 February 2018	6:30	52	49	52	48	47	4	0	Unacceptable
Saturday, 3 February 2018	7:00	51	48	52	48	45	4	0	Unacceptable
Saturday, 3 February 2018	7:30	51	50	53	49	47	4	0	Unacceptable
Saturday, 3 February 2018	8:00	52	50	54	50	46	5	0	Unacceptable
Saturday, 3 February 2018	8:30	51	51	55	52	48	5	0	Unacceptable
Saturday, 3 February 2018	9:00	51	50	54	49	63	4	0	Unacceptable
Saturday, 3 February 2018	9:30	51	50	54	49	48	4	0	Unacceptable
Saturday, 3 February 2018	10:00	52	52	56	53	64	5	0	Unacceptable
Saturday, 3 February 2018	10:30	53	52	56	52	50	5	0	Unacceptable
Saturday, 3 February 2018	11:00	52	52	56	53	49	5	0	Unacceptable
Saturday, 3 February 2018	11:30	53	52	56	53	49	5	0	Unacceptable
Saturday, 3 February 2018	12:00	52	52	55	53	49	5	0	Unacceptable
Saturday, 3 February 2018	12:30	52	52	55	52	49	6	0	Unacceptable
Saturday, 3 February 2018	13:00	53	52	55	53	50	6	0	Unacceptable
Saturday, 3 February 2018	13:30	53	60	55	53	49	6	0	Unacceptable
Saturday, 3 February 2018	14:00	52	51	55	53	64	6	0	Unacceptable
Saturday, 3 February 2018	14:30	53	52	55	52	60	7	0	Unacceptable
Saturday, 3 February 2018	15:00	53	52	56	52	50	7	0	Unacceptable
Saturday, 3 February 2018	15:30	52	51	55	52	50	7	0	Unacceptable
Saturday, 3 February 2018	16:00	53	52	55	52	51	7	0	Unacceptable
Saturday, 3 February 2018	16:30	53	52	54	52	51	7	0	Unacceptable
Saturday, 3 February 2018	17:00	54	54	55	54	51	7	0	Unacceptable
Saturday, 3 February 2018	17:30	54	52	56	52	51	7	0	Unacceptable
Saturday, 3 February 2018	18:00	53	52	54	52	51	7	0	Unacceptable
Saturday, 3 February 2018	18:30	61	52	56	53	50	7	0	Unacceptable
Saturday, 3 February 2018	19:00	53	51	54	51	51	8	0	Unacceptable
Saturday, 3 February 2018	19:30	53	52	54	54	65	6	0	Unacceptable
Saturday, 3 February 2018	20:00	52	51	53	51	61	6	0	Unacceptable
Saturday, 3 February 2018	20:30	57	66	52	49	50	5	0	Unacceptable
Saturday, 3 February 2018	21:00	50	49	52	49	50	5	0	Unacceptable
Saturday, 3 February 2018	21:30	59	48	52	49	60	5	0	Unacceptable
Saturday, 3 February 2018	22:00	59	48	51	48	62	4	0	Unacceptable
Saturday, 3 February 2018	22:30	60	49	52	47	62	3	0	Unacceptable
Saturday, 3 February 2018	23:00	59	49	53	51	62	2	0	Acceptable
Saturday, 3 February 2018	23:30	59	47	51	47	64	2	0	Acceptable
Saturday, 3 February 2018	0:00	59	49	50	45	64	2	0	Acceptable
Sunday, 4 February 2018	0:30	53	48	48	45	64	2	0	Acceptable
Sunday, 4 February 2018	1:00	52	50	49	47	64	2	0	Acceptable
Sunday, 4 February 2018	1:30	50	49	47	41	63	1	0	Acceptable
Sunday, 4 February 2018	2:00	48	45	47	41	63	2	0	Acceptable
Sunday, 4 February 2018	2:30	49	47	46	41	63	2	0	Acceptable
Sunday, 4 February 2018	3:00	48	45	46	42	62	2	0	Acceptable
Sunday, 4 February 2018	3:30	47	44	43	38	55	2	0	Acceptable
Sunday, 4 February 2018	4:00	49	47	47	38	56	2	0	Acceptable
Sunday, 4 February 2018	4:30	47	45	47	43	55	2	0	Acceptable
Sunday, 4 February 2018	5:00	49	46	47	42	56	2	0	Acceptable
Sunday, 4 February 2018	5:30	50	48	47	42	55	2	0	Acceptable
Sunday, 4 February 2018	6:00	49	47	48	45	55	2	0	Acceptable
Sunday, 4 February 2018	6:30	52	49	50	47	53	2	0	Acceptable
Sunday, 4 February 2018	7:00	57	50	49	46	50	1	0	Acceptable

Date	Time	Ambient noise level dB LAeq, 30mins					BOM weather data (Geelong Airport)		
		Location 1	Location 2	Location 3	Location 4	Location 5	Wind (m/s)	Rain (mm)	Data acceptability
Sunday, 4 February 2018	7:30	54	50	51	47	52	1	0	Acceptable
Sunday, 4 February 2018	8:00	60	49	52	49	54	1	0	Acceptable
Sunday, 4 February 2018	8:30	51	52	52	50	64	2	0	Acceptable
Sunday, 4 February 2018	9:00	51	49	51	47	46	2	0	Acceptable
Sunday, 4 February 2018	9:30	51	50	53	51	46	2	0	Acceptable
Sunday, 4 February 2018	10:00	53	49	53	48	64	2	0	Acceptable
Sunday, 4 February 2018	10:30	53	51	53	50	46	3	0	Acceptable
Sunday, 4 February 2018	11:00	52	50	54	50	50	3	0	Unacceptable
Sunday, 4 February 2018	11:30	53	51	54	50	45	4	0	Unacceptable
Sunday, 4 February 2018	12:00	52	51	54	50	46	4	0	Unacceptable
Sunday, 4 February 2018	12:30	52	50	53	49	47	5	0	Unacceptable
Sunday, 4 February 2018	13:00	52	50	53	49	46	5	0	Unacceptable
Sunday, 4 February 2018	13:30	52	51	54	51	46	5	0	Unacceptable
Sunday, 4 February 2018	14:00	52	50	54	50	62	5	0	Unacceptable
Sunday, 4 February 2018	14:30	53	51	53	50	61	5	0	Unacceptable
Sunday, 4 February 2018	15:00	52	50	53	49	46	5	0	Unacceptable
Sunday, 4 February 2018	15:30	52	50	53	50	47	5	0	Unacceptable
Sunday, 4 February 2018	16:00	52	51	54	51	47	5	0	Unacceptable
Sunday, 4 February 2018	16:30	52	51	54	51	48	5	0	Unacceptable
Sunday, 4 February 2018	17:00	53	52	55	52	48	6	0	Unacceptable
Sunday, 4 February 2018	17:30	53	51	53	51	52	5	0	Unacceptable
Sunday, 4 February 2018	18:00	53	50	53	51	49	6	0	Unacceptable
Sunday, 4 February 2018	18:30	53	50	53	51	47	6	0	Unacceptable
Sunday, 4 February 2018	19:00	53	50	52	50	49	6	0	Unacceptable
Sunday, 4 February 2018	19:30	57	50	53	52	63	6	0	Unacceptable
Sunday, 4 February 2018	20:00	54	52	53	51	61	5	0	Unacceptable
Sunday, 4 February 2018	20:30	57	69	52	51	64	4	0	Unacceptable
Sunday, 4 February 2018	21:00	52	59	52	55	61	4	0	Unacceptable
Sunday, 4 February 2018	21:30	51	48	52	57	62	3	0	Unacceptable
Sunday, 4 February 2018	22:00	55	47	50	56	63	3	0	Unacceptable
Sunday, 4 February 2018	22:30	51	45	48	51	62	3	0	Unacceptable
Sunday, 4 February 2018	23:00	46	44	46	44	60	4	0	Unacceptable
Sunday, 4 February 2018	23:30	47	42	44	43	60	2	0	Acceptable
Sunday, 4 February 2018	0:00	47	45	47	42	59	2	0	Acceptable
Monday, 5 February 2018	0:30	45	42	45	41	58	2	0	Acceptable
Monday, 5 February 2018	1:00	48	44	46	41	58	3	0	Unacceptable
Monday, 5 February 2018	1:30	47	49	46	39	57	2	0	Acceptable
Monday, 5 February 2018	2:00	46	50	45	40	55	2	0	Acceptable
Monday, 5 February 2018	2:30	48	44	44	39	52	1	0	Acceptable
Monday, 5 February 2018	3:00	49	45	45	41	45	2	0	Acceptable
Monday, 5 February 2018	3:30	49	46	48	41	44	1	0	Acceptable
Monday, 5 February 2018	4:00	51	48	48	45	58	0	0	Acceptable
Monday, 5 February 2018	4:30	53	49	47	42	45	0	0	Acceptable
Monday, 5 February 2018	5:00	53	49	50	46	46	0	0	Acceptable
Monday, 5 February 2018	5:30	55	51	52	49	48	1	0	Acceptable
Monday, 5 February 2018	6:00	57	54	55	51	55	1	0	Acceptable
Monday, 5 February 2018	6:30	60	57	57	54	56	1	0	Acceptable
Monday, 5 February 2018	7:00	60	57	56	54	57	1	0	Acceptable
Monday, 5 February 2018	7:30	60	56	56	53	51	1	0	Acceptable
Monday, 5 February 2018	8:00	57	55	56	53	68	1	0	Acceptable
Monday, 5 February 2018	8:30	56	54	55	52	53	1	0	Acceptable
Monday, 5 February 2018	9:00	56	52	55	51	63	2	0	Acceptable
Monday, 5 February 2018	9:30	55	53	54	50	46	1	0	Acceptable
Monday, 5 February 2018	10:00	56	51	53	51	44	1	0	Acceptable
Monday, 5 February 2018	10:30	55	51	53	50	44	2	0	Acceptable
Monday, 5 February 2018	11:00	54	51	54	50	43	2	0	Acceptable
Monday, 5 February 2018	11:30	54	51	53	51	66	2	0	Acceptable
Monday, 5 February 2018	12:00	52	50	53	49	45	3	0	Acceptable

Date	Time	Ambient noise level dB LAeq,30mins					BOM weather data (Geelong Airport)		
		Location 1	Location 2	Location 3	Location 4	Location 5	Wind (m/s)	Rain (mm)	Data acceptability
Monday, 5 February 2018	12:30	52	50	52	51	45	4	0	Unacceptable
Monday, 5 February 2018	13:00	53	51	53	50	44	3	0	Unacceptable
Monday, 5 February 2018	13:30	53	51	54	51	46	3	0	Unacceptable
Monday, 5 February 2018	14:00	54	51	54	52	46	3	0	Acceptable
Monday, 5 February 2018	14:30	54	52	55	52	66	4	0	Unacceptable
Monday, 5 February 2018	15:00	53	52	55	52	48	5	0	Unacceptable
Monday, 5 February 2018	15:30	54	53	55	51	49	6	0	Unacceptable
Monday, 5 February 2018	16:00	54	52	59	54	48	5	0	Unacceptable
Monday, 5 February 2018	16:30	57	66	57	62	59	5	0	Unacceptable
Monday, 5 February 2018	17:00	56	53	55	53	49	7	0	Unacceptable
Monday, 5 February 2018	17:30	56	54	55	52	49	6	0	Unacceptable
Monday, 5 February 2018	18:00	54	53	54	51	48	6	0	Unacceptable
Monday, 5 February 2018	18:30	54	52	54	51	63	6	0	Unacceptable
Monday, 5 February 2018	19:00	53	51	52	50	60	5	0	Unacceptable
Monday, 5 February 2018	19:30	53	52	53	49	58	6	0	Unacceptable
Monday, 5 February 2018	20:00	53	53	56	52	66	4	0	Unacceptable
Monday, 5 February 2018	20:30	55	66	54	50	63	4	0	Unacceptable
Monday, 5 February 2018	21:00	52	54	56	48	57	3	0	Unacceptable
Monday, 5 February 2018	21:30	61	55	56	48	62	2	0	Acceptable
Monday, 5 February 2018	22:00	61	54	55	50	66	3	0	Acceptable
Monday, 5 February 2018	22:30	61	53	49	46	49	2	0	Acceptable
Monday, 5 February 2018	23:00	60	53	48	47	50	1	0	Acceptable
Monday, 5 February 2018	23:30	60	52	48	45	43	1	0	Acceptable
Monday, 5 February 2018	0:00	60	52	46	44	48	1	0	Acceptable
Tuesday, 6 February 2018	0:30	60	49	45	43	43	2	0	Acceptable
Tuesday, 6 February 2018	1:00	59	48	46	42	41	2	0	Acceptable
Tuesday, 6 February 2018	1:30	59	48	43	40	41	1	0	Acceptable
Tuesday, 6 February 2018	2:00	59	48	44	39	41	2	0	Acceptable
Tuesday, 6 February 2018	2:30	59	50	44	40	42	2	0	Acceptable
Tuesday, 6 February 2018	3:00	59	47	43	39	41	3	0	Acceptable
Tuesday, 6 February 2018	3:30	58	47	46	42	43	2	0	Acceptable
Tuesday, 6 February 2018	4:00	59	49	47	43	44	1	0	Acceptable
Tuesday, 6 February 2018	4:30	60	51	50	49	44	2	0	Acceptable
Tuesday, 6 February 2018	5:00	61	52	53	49	61	2	0	Acceptable
Tuesday, 6 February 2018	5:30	61	54	54	50	49	2	0	Acceptable
Tuesday, 6 February 2018	6:00	59	54	56	52	56	2	0	Acceptable
Tuesday, 6 February 2018	6:30	58	57	58	54	57	2	0	Acceptable
Tuesday, 6 February 2018	7:00	57	55	57	54	57	2	0	Acceptable
Tuesday, 6 February 2018	7:30	55	54	58	53	52	2	0	Acceptable
Tuesday, 6 February 2018	8:00	54	53	56	55	66	2	0	Acceptable
Tuesday, 6 February 2018	8:30	54	52	56	53	61	2	0	Acceptable
Tuesday, 6 February 2018	9:00	53	52	55	50	55	3	0	Acceptable
Tuesday, 6 February 2018	9:30	53	51	54	50	48	2	0	Acceptable
Tuesday, 6 February 2018	10:00	53	51	53	50	46	3	0	Unacceptable
Tuesday, 6 February 2018	10:30	53	51	55	51	47	3	0	Unacceptable
Tuesday, 6 February 2018	11:00	53	51	54	50	45	3	0	Unacceptable
Tuesday, 6 February 2018	11:30	53	52	56	53	63	3	0	Unacceptable
Tuesday, 6 February 2018	12:00	57	56	56	56	56	3	0	Unacceptable
Tuesday, 6 February 2018	12:30	51	49	52	48	45	4	0	Unacceptable
Tuesday, 6 February 2018	13:00	54	52	55	51	46	4	0	Unacceptable
Tuesday, 6 February 2018	13:30	52	51	55	52	47	5	0	Unacceptable
Tuesday, 6 February 2018	14:00	54	52	55	54	66	5	0	Unacceptable
Tuesday, 6 February 2018	14:30	54	52	55	53	59	5	0	Unacceptable
Tuesday, 6 February 2018	15:00	53	52	55	52	48	5	0	Unacceptable
Tuesday, 6 February 2018	15:30	53	53	56	53	50	6	0	Unacceptable
Tuesday, 6 February 2018	16:00	56	54	56	55	54	6	0	Unacceptable
Tuesday, 6 February 2018	16:30	53	52	55	52	49	7	0	Unacceptable
Tuesday, 6 February 2018	17:00	54	52	55	53	49	7	0	Unacceptable

Date	Time	Ambient noise level dB L _{Aeq, 30mins}					BOM weather data (Geelong Airport)		
		Location 1	Location 2	Location 3	Location 4	Location 5	Wind (m/s)	Rain (mm)	Data acceptability
Tuesday, 6 February 2018	17:30	52	51	55	52	49	5	0	Unacceptable
Tuesday, 6 February 2018	18:00	53	51	53	51	48	5	0	Unacceptable
Tuesday, 6 February 2018	18:30	53	52	53	52	62	5	0	Unacceptable
Tuesday, 6 February 2018	19:00	51	51	53	49	46	5	0	Unacceptable
Tuesday, 6 February 2018	19:30	52	54	53	52	58	5	0	Unacceptable
Tuesday, 6 February 2018	20:00	53	51	52	49	62	4	0	Unacceptable
Tuesday, 6 February 2018	20:30	55	69	53	50	62	4	0	Unacceptable
Tuesday, 6 February 2018	21:00	59	56	53	52	49	4	0	Unacceptable
Tuesday, 6 February 2018	21:30	62	54	53	51	57	3	0	Acceptable
Tuesday, 6 February 2018	22:00	62	53	56	51	62	2	0	Acceptable
Tuesday, 6 February 2018	22:30	61	56	56	49	44	2	0	Acceptable
Tuesday, 6 February 2018	23:00	58	57	55	50	56	1	0	Acceptable
Tuesday, 6 February 2018	23:30	50	58	55	50	60	0	0	Acceptable
Tuesday, 6 February 2018	0:00	49	49	53	49	60	1	0	Acceptable
Wednesday, 7 February 2018	0:30	48	48	51	47	60	2	0	Acceptable
Wednesday, 7 February 2018	1:00	49	51	50	46	60	0	0	Acceptable
Wednesday, 7 February 2018	1:30	49	53	46	45	60	1	0	Acceptable
Wednesday, 7 February 2018	2:00	48	49	44	46	58	1	0	Acceptable
Wednesday, 7 February 2018	2:30	49	55	44	42	56	1	0	Acceptable
Wednesday, 7 February 2018	3:00	48	55	45	42	58	1	0	Acceptable
Wednesday, 7 February 2018	3:30	50	53	45	43	58	1	0	Acceptable
Wednesday, 7 February 2018	4:00	52	54	48	46	55	2	0	Acceptable
Wednesday, 7 February 2018	4:30	55	58	52	50	47	2	0	Acceptable
Wednesday, 7 February 2018	5:00	56	58	51	48	60	1	0	Acceptable
Wednesday, 7 February 2018	5:30	54	54	54	49	48	1	0	Acceptable
Wednesday, 7 February 2018	6:00	55	59	55	51	56	1	0	Acceptable
Wednesday, 7 February 2018	6:30	58	56	58	54	64	1	0	Acceptable
Wednesday, 7 February 2018	7:00	59	57	58	56	58	1	0	Acceptable
Wednesday, 7 February 2018	7:30	58	56	56	54	54	1	0	Acceptable
Wednesday, 7 February 2018	8:00	55	55	56	54	64	1	0	Acceptable
Wednesday, 7 February 2018	8:30	56	54	56	54	62	2	0	Acceptable
Wednesday, 7 February 2018	9:00	55	53	55	53	57	1	0	Acceptable
Wednesday, 7 February 2018	9:30	54	52	54	52	48	2	0	Acceptable
Wednesday, 7 February 2018	10:00	54	51	53	51	45	2	0	Acceptable
Wednesday, 7 February 2018	10:30	54	53	55	54	45	3	0	Acceptable
Wednesday, 7 February 2018	11:00	54	53	55	52	46	2	0	Acceptable
Wednesday, 7 February 2018	11:30	53	51	55	53	61	3	0	Acceptable
Wednesday, 7 February 2018	12:00	53	52	54	52	45	2	0	Acceptable
Wednesday, 7 February 2018	12:30	52	51	53	51	46	4	0	Unacceptable
Wednesday, 7 February 2018	13:00	53	50	53	52	45	3	0	Unacceptable
Wednesday, 7 February 2018	13:30	53	51	53	52	45	3	0	Acceptable
Wednesday, 7 February 2018	14:00	53	51	53	50	57	4	0	Unacceptable
Wednesday, 7 February 2018	14:30	52	51	54	53	45	5	0	Unacceptable
Wednesday, 7 February 2018	15:00	53	52	55	51	59	5	0	Unacceptable
Wednesday, 7 February 2018	15:30	53	52	55	52	47	6	0	Unacceptable
Wednesday, 7 February 2018	16:00	53	51	55	51	47	6	0	Unacceptable
Wednesday, 7 February 2018	16:30	53	52	56	52	47	6	0	Unacceptable
Wednesday, 7 February 2018	17:00	55	52	53	48	48	6	0	Unacceptable
Wednesday, 7 February 2018	17:30	55	52	54	53	48	6	0	Unacceptable
Wednesday, 7 February 2018	18:00	55	51	56	52	47	7	0	Unacceptable
Wednesday, 7 February 2018	18:30	54	52	53	53	60	6	0	Unacceptable
Wednesday, 7 February 2018	19:00	54	51	53	52	53	7	0	Unacceptable
Wednesday, 7 February 2018	19:30	54	50	52	49	58	7	0	Unacceptable
Wednesday, 7 February 2018	20:00	54	51	55	50	63	6	0	Unacceptable
Wednesday, 7 February 2018	20:30	55	65	52	50	60	6	0	Unacceptable
Wednesday, 7 February 2018	21:00	54	52	56	52	46	4	0	Unacceptable
Wednesday, 7 February 2018	21:30	53	53	60	53	47	4	0	Unacceptable
Wednesday, 7 February 2018	22:00	59	54	58	52	46	3	0	Acceptable

Date	Time	Ambient noise level dB L _{Aeq, 30mins}					BOM weather data (Geelong Airport)		
		Location 1	Location 2	Location 3	Location 4	Location 5	Wind (m/s)	Rain (mm)	Data acceptability
Wednesday, 7 February 2018	22:30	53	55	56	51	45	2	0	Acceptable
Wednesday, 7 February 2018	23:00	51	52	56	48	62	3	0	Acceptable
Wednesday, 7 February 2018	23:30	51	53	54	48	45	3	0	Acceptable
Wednesday, 7 February 2018	0:00	50	52	51	49	45	2	0	Acceptable
Thursday, 8 February 2018	0:30	54	54	52	52	45	2	0	Acceptable
Thursday, 8 February 2018	1:00	54	57	49	50	45	2	0	Acceptable
Thursday, 8 February 2018	1:30	53	59	48	53	45	1	0	Acceptable
Thursday, 8 February 2018	2:00	51	58	49	49	45	0	0	Acceptable
Thursday, 8 February 2018	2:30	47	51	48	49	46	0	0	Acceptable
Thursday, 8 February 2018	3:00	50	47	51	50	46	1	0	Acceptable
Thursday, 8 February 2018	3:30	53	51	53	51	46	1	0	Acceptable
Thursday, 8 February 2018	4:00	55	55	50	50	46	1	0	Acceptable
Thursday, 8 February 2018	4:30	56	54	52	51	46	2	0	Acceptable
Thursday, 8 February 2018	5:00	56	55	52	53	61	2	0	Acceptable
Thursday, 8 February 2018	5:30	58	56	54	52	48	3	0	Acceptable
Thursday, 8 February 2018	6:00	59	57	55	53	58	2	0	Acceptable
Thursday, 8 February 2018	6:30	58	56	56	52	61	3	0	Acceptable
Thursday, 8 February 2018	7:00	57	56	57	54	50	0	0	Acceptable
Thursday, 8 February 2018	7:30	57	56	56	54	49	0	0	Acceptable
Thursday, 8 February 2018	8:00	58	56	57	54	68	2	0	Acceptable
Thursday, 8 February 2018	8:30	58	54	56	54	61	3	0	Acceptable
Thursday, 8 February 2018	9:00	59	55	56	54	48	3	0	Acceptable
Thursday, 8 February 2018	9:30	58	54	58	53	49	2	0	Acceptable
Thursday, 8 February 2018	10:00	59	55	56	54	49	2	0	Acceptable
Thursday, 8 February 2018	10:30	59	56	56	54	49	3	0	Acceptable
Thursday, 8 February 2018	11:00	59	55	55	55	49	3	0	Unacceptable
Thursday, 8 February 2018	11:30	58	54	55	53	64	3	0	Unacceptable
Thursday, 8 February 2018	12:00	58	54	56	54	49	2	0	Acceptable
Thursday, 8 February 2018	12:30	54	52	56	54	50	4	0	Unacceptable
Thursday, 8 February 2018	13:00	54	52	55	53	49	6	0	Unacceptable
Thursday, 8 February 2018	13:30	55	53	55	54	49	5	0	Unacceptable
Thursday, 8 February 2018	14:00	55	54	60	55	62	6	0	Unacceptable
Thursday, 8 February 2018	14:30	63	56	56	56	61	5	0	Unacceptable
Thursday, 8 February 2018	15:00	54	52	55	52	49	5	0	Unacceptable
Thursday, 8 February 2018	15:30	55	53	57	53	49	5	0	Unacceptable
Thursday, 8 February 2018	16:00	56	53	55	53	49	6	0	Unacceptable
Thursday, 8 February 2018	16:30	57	53	55	54	49	6	0	Unacceptable
Thursday, 8 February 2018	17:00	56	54	56	55	49	6	0	Unacceptable
Thursday, 8 February 2018	17:30	57	54	55	53	50	6	0	Unacceptable
Thursday, 8 February 2018	18:00	56	53	56	52	49	6	0	Unacceptable
Thursday, 8 February 2018	18:30	56	54	55	52	63	7	0	Unacceptable
Thursday, 8 February 2018	19:00	55	51	54	51	61	6	0	Unacceptable
Thursday, 8 February 2018	19:30	55	53	56	52	47	6	0	Unacceptable
Thursday, 8 February 2018	20:00	54	51	54	51	69	6	0	Unacceptable
Thursday, 8 February 2018	20:30	54	51	52	51	61	5	0	Unacceptable
Thursday, 8 February 2018	21:00	53	50	53	54	48	4	0	Unacceptable
Thursday, 8 February 2018	21:30	53	51	55	55	51	3	0	Acceptable
Thursday, 8 February 2018	22:00	54	53	54	54	63	3	0	Acceptable
Thursday, 8 February 2018	22:30	55	51	55	52	46	1	0	Acceptable
Thursday, 8 February 2018	23:00	52	48	48	50	48	1	0	Acceptable
Thursday, 8 February 2018	23:30	46	46	50	50	47	2	0	Acceptable
Thursday, 8 February 2018	0:00	46	47	50	49	44	1	0	Acceptable
Friday, 9 February 2018	0:30	47	51	49	49	45	1	0	Acceptable
Friday, 9 February 2018	1:00	50	51	46	49	47	1	0	Acceptable
Friday, 9 February 2018	1:30	52	47	46	49	44	1	0	Acceptable
Friday, 9 February 2018	2:00	54	42	47	47	40	2	0	Acceptable
Friday, 9 February 2018	2:30	53	44	47	47	44	3	0	Unacceptable
Friday, 9 February 2018	3:00	54	45	48	47	48	2	0	Acceptable

Date	Time	Ambient noise level dB L _{Aeq, 30mins}					BOM weather data (Geelong Airport)		
		Location 1	Location 2	Location 3	Location 4	Location 5	Wind (m/s)	Rain (mm)	Data acceptability
Friday, 9 February 2018	3:30	53	47	48	45	42	3	0	Unacceptable
Friday, 9 February 2018	4:00	55	49	49	47	59	3	0	Acceptable
Friday, 9 February 2018	4:30	51	48	48	47	44	3	0	Acceptable
Friday, 9 February 2018	5:00	54	50	52	49	45	3	0	Acceptable
Friday, 9 February 2018	5:30	54	52	52	50	45	4	0	Unacceptable
Friday, 9 February 2018	6:00	55	53	55	52	56	3	0	Unacceptable
Friday, 9 February 2018	6:30	56	54	57	53	64	4	0	Unacceptable
Friday, 9 February 2018	7:00	56	54	58	55	60	3	0	Acceptable
Friday, 9 February 2018	7:30	57	55	58	55	51	3	0	Acceptable
Friday, 9 February 2018	8:00	56	54	57	55	65	3	0	Unacceptable
Friday, 9 February 2018	8:30	55	54	57	55	65	3	0	Unacceptable
Friday, 9 February 2018	9:00	54	52	55	52	50	4	0	Unacceptable
Friday, 9 February 2018	9:30	55	53	56	53	50	3	0	Acceptable
Friday, 9 February 2018	10:00	55	53	57	60	49	3	0	Unacceptable
Friday, 9 February 2018	10:30	55	53	56	53	49	3	0	Acceptable
Friday, 9 February 2018	11:00	56	59	56	53	49	3	0	Acceptable
Friday, 9 February 2018	11:30	57	55	52	53	63	3	0	Unacceptable